

*SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:*

# Bostik, Inc

11320 W. Watertown Plank Road , , Wauwatosa, WI, United States

For the following product(s):

See Addendum

The product(s) meets all of the necessary qualifications to be certified for the following claim:

## FloorScore®

Indoor Air quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017); Hong Kong Air Pollution Control (VOC) Regulation.

Standard Product Application Amount: 120 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Greater than/equal to 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-08382

Valid from: February 10, 2023 to February 29, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

## Certification Addendum

### Bostik, Inc

Certification: Registration # SCS-FS-08382 | Valid from: February 10, 2023 to February 29, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.

Addendum  
Conformance: **FloorScore®**

Indoor Air quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017); Hong Kong Air Pollution Control (VOC) Regulation.

Standard Product Application Amount: 120 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Greater than/equal to 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Products: **Adhesives:**

(Sealants)

PRO-MS 50™, Grip N Grab™