

# Confirmation

## LEED

Le 13 décembre 2018, Eurofins Product Testing A/S a reçu un échantillon de adhésif pour sols référencé:

### ACRYMANG E

fourni par

### Bostik SA

L'échantillon a été fourni comme étant représentatif de la production, et a été testé selon les méthodes de tests concernées ISO 16000, EN 16516, ISO 11890-1 et ASTM D2369 et EPA method 24 (Confer rapport d'essai n° 392-2018-00515801\_G\_EN\_02 et 392-2018-00215701\_XG\_FR\_02).

**Les résultats des tests effectués sur l'adhésif indiquent que le produit satisfait les exigences du LEED v4 relatif aux émissions de COV et de teneur en COV, à savoir les spécifications suivantes:**

**Spécifications sur les émissions de COV dans l'EQ-credit LEED "Low-emitting products":**

- Exigences du EMICODE 2017 (EC1) et de la valeur limite d'émission en formaldéhyde inférieure à 10 µg/m<sup>3</sup> après 28 jours satisfaites et une concentration en COV totaux inférieure à 0,5 mg/m<sup>3</sup>.

**Spécifications sur la teneur en COV dans l'EQ-credit LEED "Low-emitting products":**

- Exigences de la règle 1168 du SCAQMD (2005) satisfaites

18 mars 2019



Janne Rothmann Norup  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*