

Confirmation

LEED

Le 10 août 2018, Eurofins Product Testing A/S a reçu un échantillon d'adhésif référencé:

STIX P956 2K

fourni par

Bostik S.A.

L'échantillon a été fourni comme étant représentatif de la production, et a été testé selon les méthodes de tests concernées ISO 16000, EN 16516 et ASTM D2369 (Confer rapport d'essai n° 392-2018-00307002_G_FR_02 and 392-2018-00470106_XG_FR_02).

Les résultats des tests effectués sur l'adhésif indiquent que le produit satisfait les exigences du LEED v4 relatif aux émissions de COV et de teneur en COV, à savoir les spécifications suivantes:

Spécifications sur les émissions de COV dans l'EQ-credit LEED "Low-emitting products":

- Exigences du EMICODE 2017 (EC1 PLUS), et de la valeur limite d'émission en formaldéhyde inférieure à 10 µg/m³ après 28 jours satisfaites.


Spécifications sur la teneur en COV dans l'EQ-credit LEED "Low-emitting products":

- Exigences de la règle 1168 du SCAQMD (2005) satisfaites

26 mai 2020



Janne Rothmann Norup
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.