



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon, Wade Rd, Basingstoke RG24 8AH, United Kingdom

Certificate of constancy of performance 0843-CPR-0524

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Bostik FP 360 Putty Cord

Penetration Seal Classified for use in flexible walls and rigid floors

A flexible pad used to reinstate the fire resistance performance of wall and floor constructions where they have been provided with apertures for the penetration of insulated or uninsulated metallic pipes, cables, and pipes or cables into socket boxes, on both sides of the wall. The Bostik FP 360 Putty Cord is supplied precut to size with a peel off strip to both faces to prevent it from bonding materials other than for the desired application. The Bostik FP 360 Putty Cord is installed by removing the peelable strips and wrapping the pad around the socket box where it penetrates the face of the wall and covering the back face of the box (at the end of the pipe). When installing around service penetrations, the Bostik FP 360 Putty Cord is installed by removing the peelable strips and wrapping the pad around the service where it penetrates the face of the wall or floor.

placed on the market under the name or trade mark of

Bostik BV

Denariusstraat 11, 4903 RC Oosterhout, The Netherlands

and produced in the manufacturing plant(s)

A/003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 19/0388, issued on 23/07/2020

and

EAD 350454-00-1104, September 2017

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 12th July 2019 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

23rd July 2020

Mr. Chris Johnson, Staff Engineer

UL International (UK) Ltd
Kingsland Business Park, Unit 1-3 Horizon, Wade Rd,
Basingstoke RG24 8AH, United Kingdom

27-CP-F0855 Issue: 3.0



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon,
Wade Rd, Basingstoke RG24 8AH, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0524

Product/Device description: Bostik FP 360 Putty Cord

Applicant designation: Bostik BV, Denariusstraat 11, 4903 RC Oosterhout, The Netherlands

Product Information

Bostik FP 360 Putty Cord

The referenced product complies with:

A – All the relevant requirements as per ETA 19/0388

ETA issue dates:

ETA 19/0388, issued 23/07/2020

23rd July 2020

Mr. Chris Johnson, Staff Engineer