

Confirmation

LEED

On 20 April 2015, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

SADERTECH V8

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00118402B + 392-2015-00118502).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days


VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1168 (2005)

10 December 2015



Thomas Bjerring
Analytical Service Manager



Janne R. Norup
Chemist