

# Confirmation

## LEED

Le 13 décembre 2018, Eurofins Product Testing A/S a reçu un échantillon adhésif pour sols référencé:

### **DAL TACK**

fourni par

### **Bostik SA**

L'échantillon a été fourni comme étant représentatif de la production, et a été testé selon les méthodes de tests concernées ISO 16000, EMICODE, EN 16516 et ASTM D2369 (Confer rapport d'essai n° 392-2018-00515802\_G\_FR et 392-2019-00011201\_XG\_FR).

**Les résultats des tests effectués sur l'échantillon indiquent que le produit satisfait les exigences du LEED v4 relatif aux émissions de COV et de teneur en COV, à savoir les spécifications suivantes:**

**Spécifications sur les émissions de COV dans l'EQ-credit LEED "Low-emitting products":**

- Exigences de EMICODE 2017, et la limite de formaldéhyde de 10 ug / m<sup>3</sup> après 28 jours.


**Spécifications sur la teneur en COV dans l'EQ-credit LEED "Low-emitting products":**

- Exigences de la règle 1168 du SCAQMD (2005) satisfaites

14 février 2019



Nanna Boholm  
Analytical Chemist



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*