

Confirmation

LEED

Le 1 juillet 2015, Eurofins Product Testing A/S a reçu un échantillon enduit lissant référencé :

SL C730 FIBRE

fourni par

Bostik SA


L'échantillon a été fourni comme étant représentatif de la production, et a été testé selon les méthodes de tests concernées ISO 16000 (Confer rapport d'essai n° 392-2015-00202802B_FR_02 et licence de certification EMICODE EC 1 PLUS 6264/24.02.97).

Les résultats des tests effectués sur l'échantillon indiquent que le produit satisfait les exigences du LEED v4 relatif aux émissions de COV et de teneur en COV, à savoir les spécifications suivantes:

Spécifications sur les émissions de COV dans l'EQ-credit LEED "Low-emitting products":

- Les exigences d'EMICODE 2013 (EC 1 PLUS) et la limite de formaldéhyde de 10 µg / m³ après 28 jours.

3 juillet 2020



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.