

# Confirmation

## LEED

On 1 July 2015, Eurofins Product Testing A/S received a sample of levelling compound with the product name:

### SL C340 LEVEL PLUS

supplied by

### Bostik SA


The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000 testing standards (See test report no. 392-2015-00202803B\_03 and EMICODE EC1 PLUS certificate license no. 11869/24.02.97).

**The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of EMICODE 2013 (EC 1 PLUS), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

2 July 2020



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry