

# Attestation

## BREEAM

On 2 February 2021, Eurofins Product Testing A/S received a sample of leveling compound with the product name:

### **Bostik SLC 950 Renoquick**

supplied by

### **BOSTIK SA**


The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in GEV (EMICODE) in its version of April 2020: EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 (See test report no. 392-2021-00058505\_G\_EN).

**The tested product complies with the “Exemplary Level” requirements of GEV cat. EC 1 PLUS (version of April 2020) as required by BREEAM International (GN22).**

29 March 2021



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry