

# Attestation

## EMICODE

On 2 February 2021, Eurofins Product Testing A/S received a sample of levelling compound with the product name:

### **Bostik SLC 950 Renoquick**

supplied by

**BOSTIK SA**

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by April 2020. See report No. 392-2021-00058505\_G\_EN.

#### **Evaluation of the test result according to EC 1 PLUS:**

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 750 µg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was below the limit of 60 µg/m<sup>3</sup>.
- The sum of SVOC after 28 days was below the limit of 40 µg/m<sup>3</sup>.
- The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m<sup>3</sup>. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 40 µg/m<sup>3</sup>.


This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

29 March 2021



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry