

Confirmation

LEED v4 and v.4 BETA

On 2 February 2021, Eurofins Product Testing A/S received a sample of leveling compound with the product name:

Bostik SLC 950 Renoquick

supplied by

BOSTIK SA

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2021-00058505_G_EN and EMICODE EC1 PLUS certificate license no. 13399/24.02.97).

The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED v4.1 BETA (February 2021) projects outside the US by showing compliance with the specifications for VOC emissions by complying with:


VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects outside the US:

- The requirements of LEED v4.1 BETA (February 2021) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below or equal to 1 and having a TVOC according to EN 16516 below or equal to 1,000 $\mu\text{g}/\text{m}^3$, a sum of VOC without LCI less than 100 $\mu\text{g}/\text{m}^3$ and a formaldehyde emission below or equal to 10 $\mu\text{g}/\text{m}^3$; all after 28 days.
- The requirements of LEED v4 by complying with:
 - The requirements of EMICODE, version of April 2020, (EC 1 PLUS) with the additional formaldehyde limit of 10 $\mu\text{g}/\text{m}^3$ after 28 days.

10 May 2021



Pernille Krintel
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.