

# Confirmation

## LEED v4.1

On 15<sup>th</sup> October 2019, Eurofins Product Testing A/S received a sample of a coating with the product name:

### **Bostik FP 312 Fire Retardant Coating**

supplied by

### **Bostik B.V.**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, ISO 11890-2 testing standards in the latest versions (See test report no. 392-2019-00411502\_A\_EN\_02 and no. 392-2019-00458301\_XG\_EN\_02).

**The test results of the tested product indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of Option 2 of LEED v4.1 BETA (April 2019) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below 1 and having a TVOC according to EN 16516 below 0.5 mg/m<sup>3</sup>.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of the EU Decopaint Directive 2004/42/EC

1 May 2020



Peter Alexander Skov  
Analytical Chemist, MSc. Eng. Chemistry



Janne Rothmann Norup  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*