

# Attestation

## BREEAM International

On 3 July 2020, Eurofins Product Testing A/S received a sample of flooring adhesive with the product name:

### STIX A600 EVOLUTION

supplied by

### BOSTIK S.A.

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards EN 16516, EN 16402 ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 respectively (See test report no. 392-2020-00295301\_G\_EN\_rev1).

**Evaluation of the emission results according to the exemplary level emission criteria (table 18) of: BREEAM Int.: Hea 02 Indoor air quality:**

---

- Carcinogenic substances were not detectable after 28 days ( $< 0.001 \text{ mg/m}^3$ ).
  - The sum of VOC ("TVOC") after 28 days was below the limit of  $0.3 \text{ mg/m}^3$ .
  - The sum of SVOC after 28 days was below the limit of  $0.1 \text{ mg/m}^3$ .
  - Formaldehyde after 28 days was below the limit of  $0.01 \text{ mg/m}^3$ .
- 

**The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).**

25 September 2020

  
Pernille Krintel  
Analytical Service Manager

  
Janne Rothmann Norup  
Analytical Service Manager