

Confirmation

LEED

On 3 July 2020, Eurofins Product Testing A/S received a sample of a flooring adhesive with the product name:

STIX A600 EVOLUTION

supplied by

BOSTIK S.A.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, EMICODE testing standards (See test report no. 392-2020-00295301_G_EN_rev1 and EMICODE EC1 PLUS certificate license no. 12365/24.02.97).

The test results of the tested sample indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of EMICODE 2020 (EC1 PLUS), and the formaldehyde limit of 10 µg/m³ after 28 days

21 October 2020



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.