

Attestation

BREEAM®

On 16 August 2022 Eurofins Product Testing A/S received a sample of an adhesive with the product name:

STIX A 340 LVT PROJECT

supplied by

BOSTIK SA

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 testing standards (See test report no. 392-2022-00360101_G_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:

- **BREEAM® International: Compliance with Exemplary criteria on VOC emission** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM® NOR: Compliance with Exemplary criteria on VOC emission** of BREEAM NOR: New Construction 2022, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.0 of February 2022).

22 September 2022



Liva Kjær Hansen
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager