

# Confirmation

## LEED

On 25/01/2016, Eurofins Product Testing A/S received a sample of Tape with the product name:

**BOSTIK ROLL 25/50/85 / BOSTIK ROLL 240**

supplied by

**Bostik SA**


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and AgBB testing standards (See test report no. 392-2016-00030201\_C).

**The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and/or VOC content by complying with:**


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

12 July 2016



Thomas Bjerring  
Analytical Service Manager



Janne R. Norup  
Chemist