

# VOC Content Test Certificate

Wednesday 04<sup>th</sup> March 2020

Supplier: Bostik Australia Pty Ltd (Level 1, 6 English Street, Essendon Fields, Victoria, 3041, Australia).

Sample Description: Fireban Hybrid FB 403

Date Tested: March 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as Referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Fireban Hybrid FB 403</b>
<b>Acoustic Sealant, Architectural Sealant, Fire Retardant Sealants and Adhesives: 250 grams per Litre</b>	<b>12 grams per Litre as VOC content per material</b>
<b>Specification</b> <b>Green Building Council of New Zealand</b> <b>Green Star Design &amp; As Built NZ V1.0-13.1.1B</b> <b>Green Star Interiors NZ V1.0-12.1.1B</b>	<b>Fireban Hybrid FB 403</b>
<b>Acoustic Sealant, Architectural Sealant, Fire Retardant Sealants and Adhesives: 250 grams per Litre</b>	<b>12 grams per Litre as VOC content per material</b>
<p><i>We hereby certify that Fireban Hybrid FB 403 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia and Green Star Design, Green Building Council of New Zealand.</i></p>	



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Tuan Duong  
 BE (Chem. Eng.)  
 Consultant



Luke Morley  
 BSc (Tech)  
 Consultant

V2003001