

VOC Content Test Certificate

Wednesday 04th March 2020

Supplier: Bostik Australia Pty Ltd (Level 1, 6 English Street, Essendon Fields, Victoria, 3041,

Australia).

Sample Description: Fireban Expanda Foam FB 404

Date Tested: March 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various

Materials as Referenced by South Coast Air Quality Management District

(SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Fireban Expanda Foam FB 404
Acoustic Sealant, Architectural Sealant, Fire Retardant Sealants and Adhesives: 250 grams per Litre	2 grams per Litre as VOC content per material
Specification Green Building Council of New Zealand Green Star Design & As Built NZ V1.0-13.1.1B Green Star Interiors NZ V1.0-12.1.1B	Fireban Expanda Foam FB 404
Acoustic Sealant, Architectural Sealant, Fire Retardant Sealants and Adhesives: 250 grams per Litre	2 grams per Litre as VOC content per material

We hereby certify that Fireban Expanda Foam FB 404 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia and Green Star Design, Green Building Council of New Zealand.

Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant

Tuan Duong BE (Chem. Eng.)

Consultant

Luke Morley BSc (Tech) Consultant

V2003001