

Confirmation

LEED

On 22 August 2014, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

Dal 50

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested as multipurpose construction adhesive in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2014-00170401B and 392-2014-00085102A).

The test results of the tested adhesive indicate that the product qualifies for LEED 2009 and LEED v4 specifications on VOC emissions and/or VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1168 (2005)

30 September 2014



Maria Pelle
Chemist



Søren Ryom Villadsen
Analytical Service Manager