

Confirmation

LEED

On July 1 2015, Eurofins Product Testing A/S received a sample of a levelling compound with the product name:

Miplasol Trafic 3

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested as Ceramic Tile Adhesive in accordance with the relevant ISO 16000, AgBB, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00202703 and 392-2015-00202803A).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1168 (2005)

4 September 2015



Thomas Bjerring
Analytical Service Manager



Maria Pelle
Chemist