

# Confirmation

## LEED

Le 5 mai 2017, Eurofins Product Testing A/S a reçu un échantillon d'enduit lissant référencé:

### **Bostik Polyrag FRP**

fourni par

### **Bostik SA**

L'échantillon a été fourni comme étant représentatif de la production, et a été testé en tant que Ceramic Tile Adhesives selon les méthodes de tests concernées ISO 16000, AgBB, ISO 11890-1, ASTM D2369 et EPA method 24 (Confer rapport d'essai n° 392-2017-00157801\_A\_FR and 392-2017-00172204\_XD\_FR).

**Les résultats des tests effectués sur l'adhésif indiquent que le produit satisfait les exigences du LEED v4 relatif aux émissions de COV et de teneur en COV, à savoir les spécifications suivantes:**

**Spécifications sur les émissions de COV dans l'EQ-credit LEED "Low-emitting products":**

- Exigences du DIBt (Octobre 2010) et de l'AgBB (février 2015), et de la valeur limite d'émission en formaldéhyde inférieure à 10 µg/m<sup>3</sup> après 28 jours satisfaites

**Spécifications sur la teneur en COV dans l'EQ-credit LEED "Low-emitting products":**

- Exigences de la règle 1168 du SCAQMD (2005) satisfaites

27 juin 2017



Maria Pelle Madsen  
Analytical Chemist



Janne Rothmann Norup  
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.