

Attestation

EMICODE

On 24/02/2016, Eurofins Product Testing A/S received a sample of a tile adhesive with the product name:

MC 300 Flex

supplied by

Bostik SA

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by 24.11.2015. See report No. 392-2016-00077704_G_FR.


Evaluation of the test result according to EC 1 PLUS:

-
- o Carcinogenic substances were not detectable after 3 and after 28 days.
 - o The sum of VOC ("TVOC") after 3 days was below the limit of 750 µg/m³.
 - o The sum of VOC ("TVOC") after 28 days was below the limit of 60 µg/m³.
 - o The sum of SVOC after 28 day was below the limit of 40 µg/m³.
 - o The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.
 - o After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - o The sum of VOC without LCI-value after 28 days was below the limit of 40 µg/m³.

This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

19 April 2016


Janne R. Norup
Chemist


Thomas Bjerring
Analytical Service Manager