

# Confirmation

## LEED

On 24/02/2016, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

### MC 220 Express

supplied by

### Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, AgBB, ISO 11890-1 and ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2016-00077703\_C\_FR and 392-2016-00097003).

**The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:**


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of DIBt (October 2010) and AgBB (June 2015), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of SCAQMD rule 1168 (2005)

19 April 2016

  
Janne R. Norup  
Chimiste

  
Thomas Bjerring  
Analytical Service Manager