

Attestation

BREEAM, EN 13999

On July 1 2015, Eurofins Product Testing A/S received a sample of a primer with the product name:

Bostik Primasol R

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in EN 13999: ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 (See test report no. 392-2015-00202804D).

The tested product complies with the requirements of EN 13999:2007 after one day as required by BREEAM.

The test did not show the presence of carcinogenic compounds in classes C1A, C1B and C2.

11 August 2015



Lise L. Clement
Chemist



Maria Pelle
Chemist