



# EC CERTIFICATE

## Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon, Wade Rd, Basingstoke RG24 8AH, United Kingdom

## Certificate of constancy of performance 0843-CPR-0524

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Bostik FP 360 Putty Cord

Penetration Seal Classified for use in flexible walls and rigid floors

A flexible pad used to reinstate the fire resistance performance of wall and floor constructions where they have been provided with apertures for the penetration of insulated or uninsulated metallic pipes, cables, and pipes or cables into socket boxes, on both sides of the wall. The Bostik FP 360 Putty Cord is supplied precut to size with a peel off strip to both faces to prevent it from bonding materials other than for the desired application. The Bostik FP 360 Putty Cord is installed by removing the peelable strips and wrapping the pad around the socket box where it penetrates the face of the wall and covering the back face of the box (at the end of the pipe). When installing around service penetrations, the Bostik FP 360 Putty Cord is installed by removing the peelable strips and wrapping the pad around the service where it penetrates the face of the wall or floor.

placed on the market under the name or trade mark of

### Bostik BV

De Voerman 8, PO Box 303, 5201 AH's-Hertogenbosch, The Netherlands

and produced in the manufacturing plant(s)

A/003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

**ETA 19/0388, issued on 12/07/2019**

and

**EAD 350454-00-1104, September 2017**

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

***constancy of performance of the construction product.***

This certificate was first issued on 12<sup>th</sup> July 2019 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

12<sup>th</sup> July 2019

Mr. Chris Johnson, Staff Engineer

UL International (UK) Ltd  
Kingsland Business Park, Unit 1-3 Horizon, Wade Rd,  
Basingstoke RG24 8AH, United Kingdom

27-CP-F0855 Issue: 3.0



# EC CERTIFICATE

## Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon,  
Wade Rd, Basingstoke RG24 8AH, United Kingdom

### Annex: Detailed information sheet

Certificate Number: 0843-CPR-0524

**Product/Device description:** Bostik FP 360 Putty Cord

**Applicant designation:** Bostik BV, De Voerman 8, PO Box 303, 5201 AH's-Hertogenbosch, The Netherlands

### Product Information

Bostik FP 360 Putty Cord

The referenced product complies with:

A – All the relevant requirements as per ETA 19/0388

### ETA issue dates:

ETA 19/0388, issued 12/07/2019

12<sup>th</sup> July 2019

A handwritten signature in blue ink, appearing to read 'Chris Johnson'.

Mr. Chris Johnson, Staff Engineer