

VOC Content Test Certificate

Friday April 29th, 2011

Manufacturer: Bostik (PO Box 35093, Naenae, Lower Hutt, NZ)

Sample Description: Megalastic

Date Tested: March 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Megalastic
Timber and binding primer 30 grams per Litre as VOC content material	24gram per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1103-32a