

# VOC Content Test Certificate

Thursday December 31<sup>st</sup>, 2009

Manufacturer: Bostik New Zealand Limited (19 Eastern Hutt Road, Wingate Lower Hutt New Zealand 5019)

Sample Description: Bostik Safe Fix Premium Construction Adhesive

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p style="text-align: center;"><b>Specification</b></p> <p style="text-align: center;"><b>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</b></p>	<p style="text-align: center;"><b>Bostik Safe Fix Premium Construction Adhesive</b></p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre as VOC content material. Multipurpose Construction Adhesive 70 grams per Litre as VOC Content material.</p>	<p><b>9 grams per Litre as VOC content material</b></p>
<p style="text-align: center;"><b>Specification</b></p> <p style="text-align: center;"><b>Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11</b></p>	<p style="text-align: center;"><b>Bostik Safe Fix Premium Construction Adhesive</b></p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre as VOC content material. Multipurpose Construction Adhesive 70 grams per Litre as VOC Content material.</p>	<p><b>9 grams per Litre as VOC content material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0911-35**