

VOC Content Test Certificate

Thursday December 31st, 2009

Manufacturer: Bostik New Zealand Limited (19 Eastern Hutt Road, Wingate Lower Hutt New Zealand 5019)

Sample Description: Bostik All Purpose Silicone Sealant

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	Bostik All Purpose Silicone Sealant
New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3	
Architectural Sealant 250 grams per Litre as VOC content material.	60 grams per Litre as VOC content material
Specification	Bostik All Purpose Silicone Sealant
Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11	
Architectural Sealant 250 grams per Litre as VOC content material.	60 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0911-35