

VOC Content Test Certificate

Thursday December 31st, 2009

Manufacturer: Bostik New Zealand Limited (19 Eastern Hutt Road, Wingate Lower Hutt New Zealand 5019)

Sample Description: Bostik Seal-N-Flex FC Fast Cure PU Sealant

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|---|---|
| <p style="text-align: center;">Specification</p> <p style="text-align: center;">New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</p> | <p style="text-align: center;">Bostik Seal-N-Flex Fast Cure PU Sealant</p> |
| <p>Architectural Sealant 250 grams per Litre as VOC content material.</p> | <p>92 grams per Litre as VOC content material</p> |
| <p style="text-align: center;">Specification</p> <p style="text-align: center;">Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11</p> | <p style="text-align: center;">Bostik Seal-N-Flex Fast Cure PU Sealant</p> |
| <p>Architectural Sealant 250 grams per Litre as VOC content material.</p> | <p>92 grams per Litre as VOC content material</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0911-35