

VOC Content Test Certificate

Thursday, 18th November 2010

Manufacturer: Bostik New Zealand Limited (19 Eastern Hutt Road, Wingate Lower Hutt New Zealand 5019)

Sample Description: Bostik Tuf as Nails WB Versatile Construction Adhesive

Date Tested: May 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p style="text-align: center;">Specification</p> <p>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</p>	<p style="text-align: center;">Bostik Tuf as Nails WB Versatile Construction Adhesive</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre as VOC content material Multipurpose Construction Adhesive 70 grams per Litre as VOC content material</p>	<p>Undetected as VOC content material</p>
<p style="text-align: center;">Specification</p> <p>Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11</p>	<p style="text-align: center;">Bostik Tuf as Nails WB Versatile Construction Adhesive</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre as VOC content material Multipurpose Construction Adhesive 70 grams per Litre as VOC content material</p>	<p>Undetected as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1004-06