

# VOC Content Test Certificate

Thursday December 31<sup>st</sup>, 2009

Manufacturer: Bostik New Zealand Limited (19 Eastern Hutt Road, Wingate Lower Hutt New Zealand 5019)

Sample Description: Bostik V60 Premium Neutral Cure Silicone Sealant

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	<b>Bostik V60 Premium Neutral Cure Silicone Sealant</b>
<b>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</b>	
Architectural Sealant 250 grams per Litre as VOC content material.	<b>52 grams per Litre as VOC content material</b>
<b>Specification</b>	<b>Bostik V60 Premium Neutral Cure Silicone Sealant</b>
<b>Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11</b>	
Architectural Sealant 250 grams per Litre as VOC content material.	<b>52 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0911-35