

VOC Content Test Certificate

Wednesday August 31st, 2016

Manufacturer: Bostik New Zealand Ltd. (19 Eastern Hutt Rd, Wingate, Lower Hutt, NZ 5019)

Sample Description: ASA Silicon Range

Date Tested: April 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	ASA Silicone Range
Architectural sealants: 250 grams per Litre as VOC content per material	100 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV160861