

VOC Content Test Certificate

Wednesday, 8th July 2016

Manufacturer: Bostik New Zealand Ltd (19 Eastern Hutt Road, Wingate, Lower Hutt, New Zealand 5019).

Sample Description: Ultragrip Plasterboard Stud Adhesive

Date Tested: July 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

| | |
|--|--|
| <p>Specification</p> <p>GreenTag GreenRate v3.2*</p> | <p>Ultragrip Plasterboard Stud Adhesive</p> |
| <p>Dry Wall and Panel Adhesive: 50 grams per Litre as VOC content per material</p> | <p>14 grams per Litre as VOC content per material</p> |

*This certification is deemed acceptable by the New Zealand Green Building Council's Green Star 2009 IEQ-3 / MAT-J credits and Green Star v3 MAT-4 credits.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160704