

# VOC Content Test Certificate

Tuesday, 18<sup>th</sup> August 2015

Manufacturer: Bostik New Zealand Ltd (19 Eastern Hutt Road, Wingate, Lower Hutt, Wellington, New Zealand 5019)

Sample Description: Ceramic tile adhesive - CONFLEX

Date Tested: August 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>CONFLEX</b>
Ceramic tile adhesive  65 grams per Litre as VOC content per material	<b>&lt;1 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

**CV150822**