

VOC Content Test Certificate

Wednesday August 27th, 2014

Manufacturer: Bostik (19 Eastern Hutt Rd, Wingate, Lower Hutt NZ 5019)

Sample Description: Simson ISR 70-05

Date Tested: March 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Simson ISR 70-05</p>
<p>Architectural sealants* 250 grams per Litre as VOC content per material</p>	<p align="center">19 grams per Litre as VOC content per material</p>

*Sealants used to enhance the fire and water-proofing properties are included



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130307a