

Confirmation

LEED

On 08.04.2014, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

Bostik GREEN CONTACT

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with ISO 16000 and the AgBB test protocol.

The test results of the tested adhesive indicate that the product qualifies for LEED v4 specifications on VOC emissions with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of DIBt (October 2010) and AgBB (June 2012), and the formaldehyde limit of 10 µg/m³ after 28 days (See test report no. 392-2014-00058401A)

20 May 2014



Søren Ryom Villadsen
Analytical Service Manager

Confirmation

LEED