

Attestation

BREEAM International

On 18 June 2020, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

FIX A570 MULTI TACK

supplied by

BOSTIK SA

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (See test report no. 392-2020-00267401_G_EN).

Evaluation of the emission results according to the exemplary level emission criteria (table 18) of: BREEAM Int.: Hea 02 Indoor air quality:

- Carcinogenic substances were not detectable after 28 days ($< 0.001 \text{ mg/m}^3$)
 - The sum of VOC ("TVOC") after 28 days was below the limit of 0.3 mg/m^3
 - The sum of SVOC after 28 days was below the limit of 0.1 mg/m^3
 - Formaldehyde after 28 days was below the limit of 0.01 mg/m^3
-

The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).

11 August 2020



Peter Alexander Skov
Analytical Chemist, MSc. Eng. Chemistry



Janne Rothmann Norup
Analytical Service Manager