

Confirmation

LEED

On 18 June 2020, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

FIX A570 MULTI TACK

supplied by

BOSTIK SA

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, GEV EMICODE (April 2020) testing standards (See test report no. 392-2020-00267401_G_EN and EMICODE EC1 PLUS certificate license no. 6267/24.02.97).

The test results of the tested sample indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of EMICODE 2020 (EC1 PLUS), and the formaldehyde limit of 10 µg/m³ after 28 days

31 August 2020



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.