

Confirmation

LEED

On 5 May 2017, Eurofins Product Testing A/S received a sample of a screed with the product name:

SL C960 XL

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested as Ceramic Tile Adhesives in accordance with the relevant AgBB, ASTM D2369 testing standards (See test report no. 392-2017-00157801_A_EN_02 and 392-2017-172201_XD_EN_02).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of DIBt (October 2010) and AgBB (February 2015), and the formaldehyde limit of 10 µg/m³ after 28 days

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

26 May 2020



Maria Pelle Madsen
Analytical Chemist



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.