

Confirmation

LEED

On 13 December 2018, Eurofins Product Testing A/S received a sample of a flooring adhesive with the product name:

STIX A100 PROJECT

supplied by

Bostik SA

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no.392-2018-00515801_G_EN_04 and EMICODE EC 1 certificate license no. 11561/24.02.97).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of EMICODE 2017 (EC1), and the formaldehyde limit of 10 µg/m³ after 28 days and a TVOC below 0.5 mg/m³

26 May 2020



Janne Rothmann Norup
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.