

Confirmation

LEED

On 20 April 2015, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

STIX A800 PREMIUM

supplied by

Bostik SA


The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000 testing standards (See test report no. 392-2015-00118402A_04 and EMICODE EC1 PLUS certificate license no. 6270/24.02.97).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of EMICODE 2013 (EC1 PLUS), and the formaldehyde limit of 10 $\mu\text{g}/\text{m}^3$ after 28 days

20 April 2020



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry