

# Confirmation

## LEED

On 10 August 2018, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

**STIX P956 2K**

supplied by

**Bostik S.A.**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516 and ASTM D2369 testing standards (See test report no. 392-2018-00307002\_G\_EN\_02 and 392-2018-00470106\_XG\_EN\_02).

**The test results of the tested adhesive indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of EMICODE 2017 (EC1 PLUS), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of SCAQMD rule 1168 (2005)

26 May 2020



Janne Rothmann Norup  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*