

# Attestation

## BREEAM, EN 13999

On 20 April 2015, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

### **Miplafix 800**

supplied by

### **Bostik SA**

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in EN 13999: ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 (See test report no. 392-2015-00118402C).

**The tested product complies with the requirements of EN 13999:2007 after one day as required by BREEAM.**

**The test did not show the presence of carcinogenic compounds in classes C1A, C1B and C2.**

11 June 2015



---

Maria Pelle  
Chemist